

CERTIFICATE OF ANALYSIS



VAT no: 4530237439

SANAS Accredited Testing Laboratory No: T0375

Reg no: 2007/006925/23

Water Analytical Laboratory cc
3 Hulett Street Plankenbrug Industrial STELLENBOSCH 7600.
Tel: +27 21 883 8905 Fax: +27 86 503 5003 Cell: + 27 76 6260344 Email: lab@walab.co.za
P.O. Box 2527 PAARL 7620

Ref: Fileserver\Reports 2017\Atlantis Group.1

Your ref:

07 November 2017

Atlantis Group
8th Avenue, Industrial Estate
MAITLAND
7405

Attention: Ginette

Samples taken: 01 November 2017
Samples received and analysed: 01 November 2017
Analysis completed: 03 November 2017

Sample description: Water

Sample	Heterotrophic P/C per 1ml at 35°C	Total coliforms per 100 ml	Faecal coliforms per 100 ml	<i>E.coli</i> per 100 ml
Before (31/10/2017)	19 100	±10 300	6	6
After	20	14	None found	None found

Not tested/requested indicated by: (-)

Sample temperature: 20;+

Ms ETHNE CARLSE
MICROBIOLOGIST

page 1 of 1

Accredited method/techniques used: Biochemical methods, WAL M1 (heterotrophic plate count); WAL M3 (faecal coliform); enzyme substrate, WAL M4 (*E.coli*). Chromogenic agar (ecoli-coliforms) method WAL M5 in parallel with method WAL M2 and WAL M4

This report relates to the samples tested and identified in this report. The laboratory does not accept responsibility for the quality of the samples in terms of temperature during transit, age, etc. supplied to the laboratory or for comments added by another party. Test reports shall be reproduced in full and not only in part. Written approval must be obtained in writing from the Laboratory manager before certain parts of the report is published or reproduced.

Please arrange with the laboratory BEFORE taking the samples. Bacteriological samples must be analysed within ± 6 hours. Samples are therefore accepted by appointment only. Please allow two days for completion of the tests. This laboratory is normally closed on **Public holidays, Saturdays and Sundays.**